

Joe Colangelo

From: Rocky Martin <hinesburgpw@gmavt.net>
Sent: Friday, February 15, 2013 10:19 AM
To: 'Brian Bertsch'; rmartin@hinesburg.org
Cc: ghendersonking@whiteandburke.com; 'Paul O'Leary'; dwhite@whiteandburke.com; hinesburghighway@gmavt.net; Joe Colangelo
Subject: RE: Commerce Street drainage changes
Attachments: 20130215102713.pdf

Hi Brian- I just met with Highway Foreman Mike Anthony about this, please include him in all correspondence at hinesburghighway@gmavt.net

See attached note-does your plan include a tee in pipe from Hannaford stormwater system to accept the 15" pipe on east side (towards Tailhook drive)? There was no note.

Thanks

Rocky

From: Brian Bertsch [<mailto:bbertsch@olearyburke.com>]
Sent: Thursday, February 14, 2013 1:29 PM
To: rmartin@hinesburg.org
Cc: ghendersonking@whiteandburke.com; Paul O'Leary; dwhite@whiteandburke.com
Subject: Commerce Street drainage changes

Hi Rocky,

Gail from David White's office is putting together a submittal which incorporates the recent utility changes for the Hannaford project. One of the changes you requested was a new catch basin to connect the new culvert pipe under Commerce Street extension and the culvert pipe from the swale which collects runoff from the mobil entrance. We looked at adding a catch basin there but there is not enough cover over the pipe to make it work. As you know typical 2-3' is needed to just build the catch basin. Instead we have shown a 'tee' connection similar to way we are collecting runoff from the swale between tailhook and commerce street. We are open to other suggestions you may have as well but think the 'tee' solution will work.

Attached is a revised plan, let us know your thoughts. Thank you,

Brian

Brian J. Bertsch, P.E., CPESC | Project Manager
O'Leary-Burke Civil Associates
1 Corporate Drive, Suite 1, Essex Jct., VT 05452
p. (802) 878-9990x106 | bbertsch@olearyburke.com