



Town of Hinesburg

Water Works Department

10632 Route 116 Hinesburg VT 05461

802.482.2281 | hinesburg.org

Town of Hinesburg Water Supply - 2014 MTBE Test Results

Complete Information Can Be Found At:

<http://hinesburg.org/waterworks>

Sample Date	Well 1	Well 3	Total Influent
2014			
12/23/14	1.9	0.7	0.9
12/09/14	2.8	2.2	3.1
11/26/14	2.3	0.7	1.1
11/12/14	2.3	0.6	1.1
10/29/14	2.2	0.8	0.8
10/15/14	1.4	1.3	0.8
10/01/14	1.3	0.8	0.8
9/17/14	2.7	1.5	3.3
9/04/14	2.1	0.7	1.1
8/22/14	0.8	1.2	1.2
8/06/14	1.5	1.2	1.3
7/23/14	2.6	2.1	4.1
7/11/14	1.9	2.5	4.5
6/23/14	1.6	4.4	2.6
6/10/14	2.0	2.7	3.9
5/30/14	2.0	2.2	3.6
5/16/14	1.4	2.2	3.4
4/30/14	1.9	1.1	1.2
4/17/14	5.4	2.5	3.8
4/02/14	1.8	0.7	0.9

3/19/14	1.7	2.1	3.9
3/07/14	2.1	1.1	0.8
2/21/14	1.6	1.6	1.2
2/04/14	1.7	1.8	2.8
1/22/14	1.8	2.4	3.6
1/13/14	2.8	1.8	4.1
Results in Parts Per Billion (PPB)			

Note: Currently the United States Environmental Protection Agency's (EPA) limit for MTBE in the water supply is 40 ppb (parts per billion). The two wells the Town of Hinesburg uses in the Village for the municipal water supply have been well below this level. The highest reading was measured at about 5 ppb.

The Town of Hinesburg has hired the environmental consulting firm of Heindel and Noyes to perform the ongoing sampling and monitoring of these two town wells. Both parties feel that the EPA benchmark level of 40 ppb is too high and have set the action limit to 15 ppb.

Testing of the water will be performed bi-weekly. For more information contact the Hinesburg Department of Buildings & Facilities at (802) 482-2281 ext. 229